



TS IEC 62804-1:2015

Photovoltaic (PV) Modules - Test Methods for the detection of potential-induced degradation

Part 1: Crystalline silicone
Confirmation of test results

Ref.: TRPVM-ET-20190521-077

Applicant: Sharp Corporation
282-1, Hajikami, Katsuragi-shi 639-2198 NARA (NARA-KEN),
Japan

Product: Crystalline Silicon Photovoltaic (PV)-Modules

Type:

A)	ND-AF330C
B)	ND-AF330E
C)	NU-AF365E
D)	NU-AF370E
E)	NU-AF345H

Manufacturer: JINZHOU YANGGUANG ENERGY CO., LTD.

Standard: TS IEC 62804-1:2015

Test conditions

Testing time:	96 h
Chamber temperature:	60°C
Relative Humidity:	85 %
Potential to ground:	- 1500 V

Pass criteria

Power degradation:	< 5%
Dry Insulation:	> 40 MΩm ²
Wet insulation:	> 40 MΩm ²
Ground continuity:	< 0.1Ω



Summary of test results:

Maximum power degradation:	allowed	max. 5 %
	measured	max. 0.8 %

The measured degradation is below the allowed degradation.

Dry insulation resistance:	required	20.6 MΩ
	measured	>500 MΩ

Wet insulation resistance:	required	20.6 MΩ
	measured	>500 MΩ

The measured wet insulation resistance is above the limit.

Ground continuity test:	required	max. 0.1Ω
	measured	max. 0.005Ω

Visual inspection:	No findings
---------------------------	-------------

The complete test results and the relevant bill of materials are given in Test Report No.: TRPVM-ET-20190920-165-1, TRPVM-ET-20190920-165-2 and TRPVM-ET-20190920-165-3.

VDE Renewables GmbH


Ariel Ma


Dean Wen

2019-09-30

