

Sharp Electronics GmbH, Nagelsweg 33-35, 20097 Hamburg

Information to Customers


T: +49 (0) 40 / 2376 - 2650
F: +49 (0) 40 / 2376 - 15 - 2920
E: solarservice@sharp.eu
W: www.sharp.eu

Hamburg, 06.03.2019

Confirmation of mounting positions for SHARP Solar Modules NDAKxxx(h) and NUAKxxx(H)

Dear Sirs,

Sharp Electronics GmbH confirms, that the below mentioned Module series could be mounted with clamps under below described conditions as an extension of the actual Installation Manual. Furthermore, the test load according Mechanical Load Test (MQT16) of EN61215-2 is 2.400Pa. The installation manual attached to the Modules remains valid. The Product- and Power Output Guarantee in the version at the date of purchase by the end user remains valid. Damages caused by mechanical overload are excluded from the Product Guarantee.



Clamping on long side:

ND-AKxxx(H), NU-AKxxx(H)

L between 0 and $\frac{1}{4}$ * Module length from the corner

With best regards

Peter Thiele
President

Klaus Schaefer
Manager Solar Service Support Department