



No. Z2 092315 0006 Rev. 00

282-1 HAJIKAMI
KATSURAGI-SHI NARA
639-2198 JAPAN

105160, 105186, 105185

Certification Mark:



Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-crystalline Silicon Photovoltaic (PV) Modules

NU-AC310, NU-AF365, NU-AF370
NU-AF345H, NU-AF365E, NU-AF370E

Rated Output Power at STC:
310W, 365W, 370W, 345W, 365W, 370W
Safety Class: Class II
Maximum System Voltage: 1000V DC or 1500V DC
Construction: Framed, with Junction box, cable and connector.
Fire Safety Class: Class C according to UL790.

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)
IEC 62716(ed.1)
IEC 61701(ed.2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Valid until: 2024-07-22

(Xinlian LUO)